



Certificate of Compliance

Certificate: 1436092 (LR 52299)

Master Contract: 150247

Project: 2276381

Date Issued: 2010/02/19

Issued to: Applied Strobe Technology Company

Limited
8345 Stanley Ave
Niagara Falls, ON L2E 6X8
Canada
Attention: Mike Slovak

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ken McDowell, C.E.T.

Issued by: Ken McDowell, C.E.T.

PRODUCTS

CLASS 3425 85 - LUMINAIRES - Luminaires - Miscellaneous - Certified to US Standards

CLASS 3425 05 - LUMINAIRES - Luminaires - Miscellaneous

Safety warning lights, AST Series, rated for 120V ac, or 240V ac, 60Hz input; or 10-30V dc or 50-60V dc or 90-130V dc or 90-130V ac or 220-250V dc or 220-250V ac, flashing type lamp, suitable for wet locations, surface mounted, for 1- Xenon type flash tube which is replaceable *.

* Flash tube assembled to a polarized connector by the manufacturer.

Suffixes are used to denote construction and supply circuit type.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 250.0-08 - Luminaires

UL Std No. 1638 4th Ed - Visual Signaling Appliances